



# Registration Eextificate

Carpet Name: CHECK IT OUT

Licensee: INTERFACE

Licence Number: 1016 Label Number: 24313

ACCS Contract Grading: CEHD 4\*
ACCS Residential Grading: NONE
Suitable for Stairs: Yes

Date Graded: 24-01-2024



**Andrew Martin** Secretary ACCS



CONTRACT

RESIDENTIAL

Administered by the Carpet Institute of Australia Limited ABN 11 006 829 303

PO Box 7172, St Kilda Road, Melbourne Victoria 3004 Tel: (03) 9804 5559 Email: info@carpetoz.com.au • www.carpetinstitute.com.au

This certificate remains the property of the Carpet Institute of Australia Limited.

**Carpet Details:** 

**Company: INTERFACE** 

Licence No: 1016 Office No: 7492

N/A

### Names:

CHECK IT OUT

#### **Details:**

Awarded Res Grade: NONE Awarded Con Grade: **CEHD** 4\* Registered On: 24/01/2024 Active: Yes Date In-Active: Manufacture Method: Tufted Twist Set: N/A Dyeing Method: Melt Dyed #Colours/Designs: 6/1 Other Backing Type:

Spinning System: BCF
Insect Resist Agent: N/A
Filament: 23.81

Master Product:

Felted:

## **Hexapod Scores:**

Texture		Colour		Thickness		
	WA		WA	(mm)	(%)	
1500: 4.0	0.0	4.0	0.0	0.4	8.0	
8000: 3.0	0.0	3.5	0.0	1.1	22.0	

## **ACCS Test:**

Res Con Max SPM/PH Ratio: 16 16 16 Volume Density: 12.4 12.4 20 Tuft Density: 9 9 9 Dyn Load: 5 3.5 3.5 Stat Load: 5 3.5 3.5 14 Soiling Prop: 12 12 Abrasion Res: 10 10 10

 Sub Total:
 66.4
 66.4
 90

 Panel Assess:
 15
 15
 10

 Total:
 81.4
 81.4
 100

Calc Residential Grade: REHD2 6\*
Calc Contract Grade: CHD 3\*

Test Results:

Pile Mass g/m<sup>2</sup> (oz/yd<sup>2</sup>): 1017 (30.0) SPM g/m² (oz/yd²): 619.84(18.3) Stated Pile Height (mm): 4.5 Minimum Pile Height (mm): 4.0 Maximum Pile Height (mm): 4.7 Dynamic Loading Loss (%): 0.0 Static Loading Loss (%): 0.0 Tex (g/1000m): 300 Measured Pile Thickness (mm): 4.6 39.4 Machine Gauge (Tufts/dm): Meas Tufts Perp to Selvedge: 40.0 Meas Tufts Para to Selvedge: 46.0 Treated For Soiling Resistance: No Soil Resist Inhibitor: No Stain Resist Inhibitor: No

Label No:

24313

Quality Assurance Test:

Cut Pile (%): 5
Loop Pile (%): 95
Panel Assessment Contract: 15
Panel Assessment Residential: 15
Suitable For Stairs: Yes
Tile: Yes SheetGoods: No

NBA:100

**NYLON** 

#### **Calculations**

Fibre Signature:

Pile Height(mm): 5.7Tuft Density(per dm²): 1840.0GSPM(g/m²): 419.5GSPM (abrasive) (g/m²): 275.0Soiling Propensity: 12.0 +0.0

# **OAF Values**

OAF: 4.2 Calc Density (+-5%):0.13 0.135 0.14

Benchmarks:

Base Fibre:

RHD1 0 RHD2 3.5 REHD1 3.5 REHD2 3.5

# **Environmental Classification:**

ECS: Level:

Calc B/M P/F
Acoustic: 4.6 3 PASS
Thermal: 34.1 15 PASS

VOC:

TVOC 0

#### Notes:

22/1/24 Submitted by X Translavina. 24/1/2024 Panel graded CEHD(S)  $4^*$ .