

# Environmental Certification Scheme

Carpet Name:

STUNT DOUBLE



Licensee: INTERFACE ce Number: 1016

Licence Number: 1016 Label Number: 23264

Environmental

Certification Approved: 29/03/2023

Level: 4

ACCS Contract Grading: CEHD 4\*
ACCS Residential Grading: NONE
Suitable for Stairs: Yes

Date Printed: 4/04/2023



**Andrew Martin** Secretary ACCS



Administered by the Carpet Institute of Australia Limited ABN 11 006 829 303

PO Box 7172, St Kilda Road, Melbourne Victoria 8004 Tel: (03) 9804 5559 • Fax: (03) 9804 5560 Email: info@carpetoz.com.au • www.carpetinstitute.com.au

Ziriani imo obarpotozioomiaa

**Carpet Details:** 

**Company: INTERFACE** 

Licence No: 1016 Office No: 7373

**BCF** 

N/A

23.81

#### Names:

STUNT DOUBLE

#### **Details:**

Awarded Res Grade: NONE Awarded Con Grade: **CEHD** 4\* Registered On: 27/03/2023 Active: Yes Date In-Active: Manufacture Method: Tufted Twist Set: N/A Dyeing Method: Melt Dyed #Colours/Designs: 12/ Backing Type: Latex Felted: N/A

#### **Hexapod Scores:**

Spinning System:

Master Product:

Filament:

Insect Resist Agent:

**Texture** Colour **Thickness** WA WA (mm) (%) 1500: 4.0 0.0 0.3 7.5 4.5 0.0 0.5 12.5 8000: 4.0 0.0 4.0 0.0

## **ACCS Test:**

Con Res Max SPM/PH Ratio: 14.8 16 16 Volume Density: 11.8 11.8 20 Tuft Density: 9 8.3 8.3 Dyn Load: 5 3.9 3.9 Stat Load: 4.1 5 4.1 Soiling Prop: 16 14 14 Abrasion Res: 10 10 10 Sub Total: 66.9 68.1 81 Panel Assess: 19 14 14 Total: 80.9 82.1 100 Calc Residential Grade: REHD2 6\* Calc Contract Grade: CHD 3\*

#### Test Results:

Pile Mass g/m² (oz/yd²): 746 (22.0)SPM g/m² (oz/yd²): (15.8)Stated Pile Height (mm): 540.0 Minimum Pile Height (mm): 4.4 Maximum Pile Height (mm): 4.5 Dynamic Loading Loss (%): 0.0 Static Loading Loss (%): 0.0 Tex (g/1000m): 268 Measured Pile Thickness (mm): 4.4 39.4 Machine Gauge (Tufts/dm): Meas Tufts Perp to Selvedge: 40.0 Meas Tufts Para to Selvedge: 42.0 Treated For Soiling Resistance: Yes Soil Resist Inhibitor: Yes Stain Resist Inhibitor: Yes

Label No:

23264

## Quality Assurance Test:

Cut Pile (%): 0 Loop Pile (%): 100 Panel Assessment Contract: 14 Panel Assessment Residential: 14 Suitable For Stairs: Yes Tile: Yes SheetGoods: No Fibre Signature: NBA:100

#### **Calculations**

Pile Height(mm): 6.0Tuft Density(per dm²): 1680.0GSPM(g/m²): 415.0GSPM (abrasive) (g/m²): 275.0Soiling Propensity: 12.0 +2.0

### **OAF Values**

OAF: 4.2 Calc Density (+-5%):0.12 0.122 0.13

Base Fibre: NYLON

Benchmarks:

RHD1 0 RHD2 3.5 REHD1 3.5 REHD2 3.5

## **Environmental Classification:**

ECS: Yes Level: 4

Calc B/M P/F
Acoustic: 4.4 3 PASS
Thermal: 36.1 15 PASS

VOC:

TVOC 120

# Notes:

27/3/2023 Submitted by X Translavina. 29/3/2023 Panel awarded CEHD(S) 4\* & ECS Level 4.